CERTIFICATE OF COMPLIANCE

Certificate Number	2023-03-03-E336916
Report Reference	E336916-D1011-1/A0/C0-UL
Date	2023-03-03
Issued to:	Sick AG
Applicant Company:	Erwin-Sick-Str. 1 Waldkirch, 79183 Germany
Listed Company:	Same as Applicant
This is to certify that representative samples of	The Multi Physics Box MPB10 is a condition monitoring sensor. MPB10 Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 61010-1, 3rd Edition, May 11, 2012, Revised July 19, 2019, CAN/CSA-C22.2 No. 61010-1(2012-05), 3rd Edition, with revisions through 2018-11
Additional Standards:	N/A
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information.

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/