

# **SICK** **RFU6xx Function Block**

**Block Version V2.1X**

SICK RFU6XX TCP Function Block for  
Siemens Step7 Controllers



## Version history

Version	Date	Description
V2.0	10/15/2012	Initial version
V2.1	11/26/2012	Correction of errors concerning free command and read result flag
V2.1	11/12/2013	Documentation revised (antenna selection, number of retries, error code W#16#001B)
V2.2	19/07/2016	Support multi-instance offsets > 4095

## Table of contents

<b>1 About this document</b>	<b>3</b>
1.1 Purpose of this document	3
1.2 Target group	3
<b>2 General information</b>	<b>4</b>
<b>3 Hardware configuration</b>	<b>5</b>
3.1 Supported PLC controllers	5
3.2 Establishing a connection	5
<b>4 Block description</b>	<b>8</b>
4.1 Block specifications	8
4.2 Operating principle	9
4.3 Response to errors	10
4.4 Timing	10
4.5 Value transfer	11
4.5.1 Mode	12
4.5.2 Mode 1: SOPAS-ET object trigger control	12
4.5.3 Mode 1: SOPAS-ET output format	13
4.5.4 Read tag	15
4.5.5 Write tag	16
4.5.6 Free command	18
4.5.7 Reading result	18
4.6 Receiving reading results > 200 bytes	19
<b>5 Parameters</b>	<b>21</b>
<b>6 Error codes</b>	<b>23</b>
<b>7 Examples</b>	<b>26</b>
7.1 Reading tag content	27
7.2 Writing tag content	29

**About this document**

Please read this chapter carefully before you begin working with these operating instructions and the SICK RFU6XX TCP function block.

**1.1 Purpose of this document**

These operating instructions describe how to use the SICK RFU6XX TCP function block. They are intended to guide technical personnel working for the machine manufacturer/operator through the processes of configuring and commissioning the function block.

**1.2 Target group**

These operating instructions are aimed at specialist personnel such as technicians and engineers.

## 2 General information

The "SICK RFU6XX TCP" function block is used to facilitate communication between a SIMATIC controller and a SICK RFU6xx RFID sensor. The RFU6xx communicates with the controller via a TCP connection.

The following figure shows how the function block is represented in the function block diagram (FBD) view.




Figure 1: SICK RFU6XX TCP function block

### Block functions:

- Send a trigger command (CoLa<sup>i</sup> command) via the PLC
- Receive reading results (defined in SOPAS-ET<sup>ii</sup> output format)
- Read and write transponder content
- Execute a communication test
- Communicate via freely selectable CoLa commands (CoLa-A protocol)
- Address devices that communicate with each other via CAN bus

<sup>i</sup> The command language (CoLa) is a protocol internal to SICK for communicating with SOPAS devices.

<sup>ii</sup> SOPAS-ET is an engineering tool for configuring SICK sensors.

## 3 Hardware configuration

### 3.1 Supported PLC controllers

The function block may only be operated with Simatic S7-300 and S7-400 controllers with an integrated TCP interface. Communication via a communication processor (CP module) is not supported.

### 3.2 Establishing a connection

A TCP connection to the sensor must be established before the function block can be used. For S7 controllers with an integrated IE interface, Siemens provides the following communication blocks (Standard Library → Communication Blocks):

- FB65 (TCON): To establish a TCP connection
- FB65 (TDISCON): To close down a TCP connection
- FB63 (TSEND): To send data
- FB64 (TRCV): To receive data

Figure 2 shows the FB65 call with the associated instance (DB65) in OB1. When the controller starts up, OB100 is executed once. The start bit (REQ) of FB65 is set in OB100 to establish the connection via FB65. Successful connection setup is indicated by the bit DONE = TRUE. The connection parameters for establishing a connection are saved in a data structure (UDT65).

The ID parameter of the TCON block and the instantiated UDT structure must be identical to the ID of the SICK RFU TCP block.

```

Network 1: HERSTELLEN EINER TCP VERBINDUNG | OPEN TCP CONNECTION
-----
Herstellen einer TCP Verbindung mittels FB65 (TCON)
---
Open TCP connection via FB65 (TCON)

CALL "TCON" , "INSTANCE_FB65"                                FB65 / DB65
REQ      := "TCON_PARAMETER".CONNECT.REQ                     DB2.DBX64.0
ID       := W#16#1
DONE     := "TCON_PARAMETER".CONNECT.DONE                     DB2.DBX64.1
BUSY     := "TCON_PARAMETER".CONNECT.BUSY                     DB2.DBX64.2
ERROR    := "TCON_PARAMETER".CONNECT.ERROR                     DB2.DBX64.3
STATUS   := "TCON_PARAMETER".CONNECT.STATUS                   DB2.DBW66
CONNECT := "TCON_PARAMETER".CONNECT.TCON_PARAMETER            P#DB2.DBX0.0

```

Figure 2: Using FB65 (TCON) to establish a TCP connection

The table below shows an example configuration of the UDT65.

Byte	Parameter	Data type	Start value	Description
0 - 1	block_length	WORD	W#16#0040	Length of the UDT65: 64 bytes (fixed)
2 - 3	id	WORD	W#16#0001	Reference to TCP connection. This value must be identical to the ID parameter at TCON (FB65) and to the SICK RFU TCP (FB73) block.
4	connection_type	BYTE	B#16#11	Connection type = TCP
5	active_est	BOOL	TRUE	Active connection establishment

Byte	Parameter	Data type	Start value	Description
6	local_device_id	BYTE	B#16#02	Type of TCP connection  In this case: Communication via the integrated Ethernet interface for CPUs 315-2 PN/DP and 317-2 PN/DP
7	local_tsap_id_len	BYTE	B#16#02	For connection type B#16#11 and a passive end point
8	rem_subnet_id_len	BYTE	B#16#00	Not used
9	rem_staddr_len	BYTE	B#16#04	Length of the IP address of the station (SICK device)
10	rem_tsap_id_len	BYTE	B#16#02	Fixed for connection type B#16#11
11	Next_staddr_len	BYTE	B#16#00	Used length of the next_staddr parameter (not used)
12 - 27	Local_tsap_id	Array [1..16] of BYTE	-	Number of the local port used:  [1] = High byte of the port number used represented in hex format [2] = Low byte of the port number used represented in hex format [3..16] = B#16#00
28 - 33	rem_subnet_id	Array [1..6] of BYTE	-	Not used [1..16] = B#16#0
34 - 39	Rem_staddr	Array [1..6] of BYTE	-	IP address of the RFU  For example: 192.168.10.15 [1] = B#16#C0 (192) [2] = B#16#A8 (168) [3] = B#16#0A (10) [4] = B#16#0F (15) [5-6] = B#16#00
40 - 55	Rem_tsap_id	Array [1..16] of BYTE	-	Port number of connected RFU  SICK communication port: 2112 (decimal) [1] = B#16#08 (high byte) [2] = B#16#40 (low byte) [3..16] = B#16#0
56 - 61	Next_staddr	Array [1..6] of BYTE	-	Not used  [1..6] = B#16#0
62 - 63	spare	WORD	W#16#0000	Not used

Please refer to the Step7 help system for a precise description of the UDT parameters.

The function block will only work if there is an active TCP connection to the RFU. Figure 3 shows the Step7 diagnostics screen for open communication via Industrial Ethernet. To access this screen, select "Module Status → Diagnostics → Occupied Connection Resources".




Figure 3: Communication diagnostics

## 4 Block description

The function block is an asynchronous FB, i.e., processing encompasses several function block calls. This means that the block must be called in the user program on a cyclical basis.

The RFU block encapsulates the "SICK CCOM TCP" (FB13) function block, which facilitates communication between the PLC and the sensor. FC10 (SICK COLA ACCESS) is used internally to interpret CoLa telegrams.

### 4.1 Block specifications

Block number:	FB74
Block name:	SICK RFU6XX TCP
Version:	2.2
Blocks called:	FB63 (TSEND) FB64 (TRCV) SFC20 (BLKMOV) SFB4 (TON) FB13 (SICK CCOM TCP) FC10 (SICK COLA ACCESS)
Data blocks used:	DB74 (SICK RFU DATA)
Block call:	Cyclical
Flags used:	None
Counters used:	None
Registers used:	AR1, AR2 (for multi-instance calls)
Capable of multi-instancing:	Yes
Language used for block creation:	Step7 STL
Step7 version:	Simatic Step7 V5.5

The system functions (SFCs) used in the function block must exist on the controller that is being used.

If block numbers are changed, then the corresponding calls in the SICK RFU6XX TCP block must be updated accordingly.



## 4.2 Operating principle

The following communication parameters must be specified before the RFU block can be used:

ID: Connection ID of the TCP connection. The value specified here must be the same as for the ID parameter of the TCON block and the instantiated UDT structure. See also Figure 3.

DATA: The data block (DB74) that accompanies the function block contains input and output parameters for the supported block functions. The data block must be transferred to the "DATA" input parameter of the function block.

### Executable block functions:

- Trigger on → Uses a CoLa command to open the device reading gate
- Trigger off → Uses a CoLa command to close the device reading gate
- Read tag → Reads out the transponder data
- Write tag → Writes transponder data
- Communication test → Checks whether the device can be contacted by sending command "sRIO"
- Free command → Executes a freely selectable CoLa command

To execute a block function (TRIG\_ON, RD\_TAG, etc.), the desired function must first be selected. Only one function can be executed at a time. The START\_REQ parameter must be triggered with a rising edge (signal change from logical zero to one) in order for the function to be executed. Until a valid device response is received, the REQ\_BUSY parameter signals that a response is still pending.

If the block's REQ\_DONE output parameter = TRUE, it means that the function has been successfully completed. If data was requested from the device during this function (e.g., RD\_TAG), this data is copied to the relevant data area of the accompanying user data block (DATA).

Data sent via a trigger command (TRIG\_ON, TRIG\_OFF) or directly by the device (e.g., direct trigger via a photoelectric sensor) is stored in the data block (ReadingResult.arrResult). For one PLC cycle, the RD\_DONE output parameter indicates that new data has been received. The data sent by the device can be changed or adapted in SOPAS output format (see chapter 4.5.3).

### 4.3 Response to errors

If the function block has an incorrect input value or if the input has been connected incorrectly, an error bit (ERROR) is set and an error code (ERRORCODE) is output. In this case, no further processing is carried out. The diagnostic parameters (ERROR, ERRORCODE) of the function block retain their values until a new command is started.

### 4.4 Timing




Figure 4: Timing diagram

1: Request triggered by rising edge at START\_REQ

The desired function (RD\_TAG in this case) must be selected at the same time/in advance. Only one function may be selected at once; otherwise, the function will be aborted with "ERROR".

2: Once all commands have been sent and all responses received, the function is terminated with "REQ\_DONE". If an error occurred during the function, the function is terminated with "ERROR". "ERRORCODE" contains information on the error that occurred if the function is aborted with "ERROR".

### 4.5 Value transfer

The supplied data block "SICK RFU DATA" (DB74) contains input and output parameters for all supported block functions. The data block can be renamed according to the user program. The data structure has a fixed definition and may not be modified except for the last entry (ReadingResult.arrResult) (see chapter 4.6: Receiving reading results > 200 bytes).

Address	Name	Type	Initial value	Comment
0.0		STRUCT		
+0.0	Mode	STRUCT		-- MODE --
+0.0	bMode	BOOL	FALSE	1: Use a fixed UII   0: Use the UII of the transponder in the field (IN)
+2.0	iUIILength	INT	0	Byte length of UII (IN/OUT)
+4.0	arrPC	ARRAY[1..4]		PC word (OUT)
+1.0		CHAR		
+8.0	arrUII	ARRAY[1..60]		Transponder UII (IN/OUT)
+1.0		CHAR		
+68.0	arrRSSI	ARRAY[1..4]	0	RSSI values of the 4 antennas (Internal/External)
+2.0		INT		
+76.0		END_STRUCT		
+76.0	ReadTag	STRUCT		--- READ TAG ---
+0.0	nBank	BYTE	B#16#0	Bank selection (0=RESERVED   1=UII/EPC   2=TID   3=USER) (IN)
+2.0	nStartWord	WORD	W#16#0	First word to read, starting from 0 (IN)
+4.0	nWordCount	BYTE	B#16#0	Number of words to read (IN)
+5.0	nRetry	BYTE	B#16#0	Number of retries, until failure is reported (IN)
+6.0	nAntenna	BYTE	B#16#0	Antenna mask for reading (1= Internal,2,4,8) (IN)
+8.0	iDataLength	INT	0	Byte length of the reading data (OUT)
+10.0	arrData	ARRAY[1..64]		Read data (OUT)
+1.0		BYTE		
+74.0		END_STRUCT		
+150.0	WriteTag	STRUCT		--- WRITE TAG ---
+0.0	nBank	BYTE	B#16#0	Bank selection (0=RESERVED   1=UII / EPC   2=TID   3=USER) (IN)
+2.0	nStartWord	WORD	W#16#0	First word to write, starting from 0 (IN)
+4.0	nWordCount	BYTE	B#16#0	Number of words to write (IN)
+5.0	nRetry	BYTE	B#16#0	Number of retries, until failure is reported (IN)
+6.0	nAntenna	BYTE	B#16#0	Antenna mask for writing (1= Internal,2,4,8) (IN)
+8.0	arrData	ARRAY[1..64]		Data to be written (IN)
+1.0		BYTE		
+72.0		END_STRUCT		
+222.0	FreeCommand	STRUCT		-- FREE COMMAND --
+0.0	iCommandLength	INT	0	Length of the free command (IN)
+2.0	arrCommand	ARRAY[1..100]		Command (SICK CoLa-A protocol without [STX]/[ETX] framing) (IN)
+1.0		CHAR		
+102.0	iResultLength	INT	0	Byte length of the free command result (OUT)
+104.0	arrResult	ARRAY[1..100]		Result (SICK CoLa-A protocol) (OUT)
+1.0		CHAR		
+204.0		END_STRUCT		
+426.0	ReadingResult	STRUCT		-- READING RESULT --
+0.0	nCounter	BYTE	B#16#0	This counter is incremented if a new reading result has arrived (OUT)
+2.0	iLength	INT	0	Byte length of the reading result (OUT)
+4.0	arrResult	ARRAY[1..200]		Reading result data (OUT)
+1.0		CHAR		
+204.0		END_STRUCT		
+630.0		END_STRUCT		

Figure 5: Structure of the SICK RFU DATA user data DB

### 4.5.1 Mode

The RFU can only communicate with a single transponder at any one time. For this reason, read and write commands are always addressed. The function block uses the UII (Unique Item Identifier) to identify the transponder.

The function block supports two different modes in order to determine which transponder UII is to be communicated with:

**Mode 1:** The system always communicates with the transponder which is currently in the read field. This mode can only be used when precisely one tag is located within the field. The RFU must be specially configured in SOPAS-ET (see chapters 4.5.2 and 4.5.3) for this mode.

**Mode 2:** A user-defined transponder UII is used for the purpose of communication.

Parameter	Declaration	Data type	Description
Mode.bMode	Input	BOOL	Addressing mode  FALSE: Mode 1 active TRUE: Mode 2 active
Mode.iUIILength	Input/Output	INT	Length of UII used  0 = Unaddressed read/write 1..60 = Length of UII defined in array "Mode.arrUII"  <i>The UII is determined automatically in Mode 1.</i>
Mode.arrPC	Output	ARRAY [1..4] OF CHAR	PC word of the transponder used  <i>(Mode 1 only)</i>
Mode.arrUII	Input/Output	ARRAY [1..60] OF CHAR	Transponder identifier (UII)  <i>The UII is determined automatically in Mode 1.</i>
Mode.arrRSSI	Output	ARRAY [1..4] OF INT	RSSI value (reception strength) of the transponder used <i>(Mode 1 only)</i>  [1] = RSSI value from antenna 1 (internal) [2] = RSSI value from antenna 2 (external) [3] = RSSI value from antenna 3 (external) [4] = RSSI value from antenna 4 (external)

Table 1: Mode parameters

### 4.5.2 Mode 1: SOPAS-ET object trigger control

The object trigger control settings define when the reading gate is opened or closed. The sensor sends a reading result to the PLC after each reading gate. The function block uses this mechanism in order to read out the UII, the PC word, and the RSSI values from the transponder that is being addressed.

The SOPAS-ET settings under menu item *Parameter* → *Reading Configuration* → *Object Trigger Control* must be defined so that the trigger window is opened via a SOPAS command and closed again when a "Good Read" result is received or after a defined period of time (1000 ms in this case).

Figure 6: Trigger setting (SOPAS)

#### 4.5.3 Mode 1: SOPAS-ET output format

The output format defines the content of the telegram that is sent by the device as soon as the trigger window is closed. This telegram is evaluated by the PLC and the information that is required for the address-specific reading/writing of tag data is read. In order for the function block to be used in Mode 1, the SOPAS output format must be structured as shown in Figure 7.

Figure 7: SOPAS output format

Please ensure that the format of blocks "RSAVG1...4" is set to hexadecimal (double-click the respective block). The "PCUII" block may not be changed.




Figure 8: Settings for RSSI blocks (RSAVG1...4)

Depending on the number of tags located in the receiving range of the RFU and the configured RSSI threshold, the following telegrams are sent (in ASCII format):

Case 1: One tag in field:

[STX]01;[RSSI Antenna 1] [RSSI Antenna 2] [RSSI Antenna 3] [RSSI Antenna 4]  
[PC+UII][ETX]

Case 2: More than one tag in field:

[STX]0X[ETX]

Case 3: No tags in field:

[STX]00[ETX]

#### 4.5.4 Read tag

The read tag function is used to read a defined data area of a tag. This function can only ever be applied to one tag. The selected mode determines which transponder the system communicates with (see chapter 4.5.1).

The following parameters must be set in the "ReadTag" structure before an RFID tag is read.

Parameter	Declaration	Data type	Description
ReadTag.nBank	Input	BYTE	Selection of the memory bank from which data is to be read  0 = reserved 1 = UII/EPC 2 = TID 3 = user memory
ReadTag.nStartWord	Input	WORD	First word (16 bits) to be read
ReadTag.nWordCount	Input	BYTE	Number of words (16 bits) to be read  Valid range: [1..32]
ReadTag.nRetry	Input	BYTE	Number of read attempts to be carried out  Valid range: LoNibble (retries on one channel) B#16#[0..7] HiNibble (retries on different channels) B#16#[0..5]  Example: ReadTag.iRetry = B#16#32 executes 2 retries per channel (3 <i>tries per channel</i> ) with 3 channel changes (4 <i>channels</i> ), i.e., a total of 3x4 = <b>12 attempts</b> .

Parameter	Declaration	Data type	Description																									
ReadTag.nAntenna	Input	BYTE	<p>Antenna selection for current read command. Only one antenna can be selected per command.</p> <p>A1 = antenna 1 (internal/external, depending on device type) A2 = antenna 2 (external) A3 = antenna 3 (external) A4 = antenna 4 (external)</p> <table><tr><td>Value</td><td>A4</td><td>A3</td><td>A2</td><td>A1</td></tr><tr><td>1</td><td></td><td></td><td></td><td>X</td></tr><tr><td>2</td><td></td><td></td><td>X</td><td></td></tr><tr><td>4</td><td></td><td>X</td><td></td><td></td></tr><tr><td>8</td><td>X</td><td></td><td></td><td></td></tr></table> <p>Valid range: [1, 2, 4, 8]</p>	Value	A4	A3	A2	A1	1				X	2			X		4		X			8	X			
Value	A4	A3	A2	A1																								
1				X																								
2			X																									
4		X																										
8	X																											
ReadTag.iDataLength	Output	INT	Valid length of read content in bytes. Required in order to define which content of ReadTag.arrData is valid.																									
ReadTag.arrData	Output	ARRAY [1..64] OF BYTE	Content of read data																									

Table 2: Read tag parameters

### 4.5.5 Write tag

The write tag function is used to write to a defined data area of a tag. This function can only ever be applied to one tag. The selected mode determines which transponder the system communicates with (see chapter 4.5.1).

The following parameters must be set in the "WriteTag" structure before writing to an RFID tag.

Parameter	Declaration	Data type	Description
WriteTag.nBank	Input	BYTE	<p>Selection of the memory bank from which data is to be read</p> <p>0 = reserved  1 = UII/EPC  2 = TID  3 = user memory</p>
WriteTag.nStartWord	Input	WORD	First word (16 bits) to be written
WriteTag.nWordCount	Input	BYTE	<p>Number of words (16 bits) to be written</p> <p>Valid range: [1..32]</p>



Parameter	Declaration	Data type	Description																									
WriteTag.nRetry	Input	BYTE	<p>Number of write attempts to be carried out</p> <p>Valid range: LoNibble (retries on one channel) B#16#[0..7] HiNibble (retries on different channels) B#16#[0..5]</p> <p>Example: WriteTag.iRetry = B#16#32 executes 2 retries per channel (3 <i>tries per channel</i>) with 3 channel changes (4 <i>channels</i>), i.e., a total of 3x4 = <b>12 attempts</b>.</p>																									
WriteTag.nAntenna	Input	BYTE	<p>Antenna selection for current write command. Only one antenna can be selected per command.</p> <p>A1 = antenna 1 (internal/external, depending on device type) A2 = antenna 2 (external) A3 = antenna 3 (external) A4 = antenna 4 (external)</p> <table><tr><td>Value</td><td>A4</td><td>A3</td><td>A2</td><td>A1</td></tr><tr><td>1</td><td></td><td></td><td></td><td>X</td></tr><tr><td>2</td><td></td><td></td><td>X</td><td></td></tr><tr><td>4</td><td></td><td>X</td><td></td><td></td></tr><tr><td>8</td><td>X</td><td></td><td></td><td></td></tr></table> <p>Valid range: [1, 2, 4, 8]</p>	Value	A4	A3	A2	A1	1				X	2			X		4		X			8	X			
Value	A4	A3	A2	A1																								
1				X																								
2			X																									
4		X																										
8	X																											
WriteTag.arrData	Output	ARRAY [1..64] OF BYTE	Data to be written to the selected tag area																									

Table 3: Write tag parameters

### 4.5.6 Free command

The free command allows you to communicate with the RFU via a valid CoLa command. For this to happen, the command must be stored in the "arrCommand" parameter of the "FreeCommand" structure. The character length of the command to be transmitted is written to the "iCommandLength" parameter. The commands can be obtained from the device description or SOPAS-ET.

Parameter	Declaration	Data type	Description
FreeCommand. iCommandLength	Input	INT	Character length of the CoLa command to be transmitted  Valid range [1..100]
FreeCommand. arrCommand	Input	ARRAY [1..100] OF CHAR	Freely selectable CoLa command (for commands, see device documentation)
FreeCommand. iResultLength	Output	INT	Byte length of received CoLa telegram
FreeCommand. arrResult	Output	ARRAY [1..100] OF CHAR	Response to the transmitted CoLa telegram

Table 4: Free command parameters

### 4.5.7 Reading result

The "ReadingResult.arrResult" array stores data that is sent via a trigger command (TRIG\_ON, TRIG\_OFF) or directly from the device (e.g., direct trigger via photoelectric sensor). The RD\_DONE output parameter signals whether data has been received.

Parameter	Declaration	Data type	Description
ReadingResult. nCounter	Output	BYTE	The receive counter is incremented by one as soon as a new reading result is received.  Value range: [0x00..0xFF]
ReadingResult. iLength	Output	INT	Byte length of received reading result
ReadingResult. arrResult	Output	ARRAY [1..200] of BYTE	Response to a trigger signal (can be defined via the SOPAS output format)  The maximum length of the received data is 200 bytes. Chapter 4.6 describes the procedure for receiving longer data telegrams.

Table 5: Reading result parameters

## 4.6 Receiving reading results > 200 bytes

The function block is designed to receive reading results up to a length of 200 bytes. If longer data is to be received, the function block must be changed at the points indicated below.

### Changes in SICK RFU DATA data block:


The length of the "ReadingResult.arrResult" array in the user data block supplied (DB74) must be set so that the reading result to be received fits into the data area of the variable.

+426.0	ReadingResult	STRUCT		-- READING RESULT --
+0.0	nCounter	BYTE	B#16#0	This counter is incremented if a new reading result has arrived (OUT)
+2.0	iLength	INT	0	Byte length of the reading result (OUT)
+4.0	arrResult	ARRAY[1..200]		Reading result data (OUT)
+1.0		CHAR		
=204.0		END_STRUCT		

Figure 9: Receiving reading results > 200 bytes (change to data block)

Changes in SICK RFU6XX TCP function block:

In the static area of the variable overview, the length of the "arrRecord" variable must be adapted so that the reading result fits into the data area of the variable. The array is not allowed to be less than 300 bytes in length, but must be greater than or equal to the length of "ReadingResult.arrResult".



Contents Of: 'Environment\Interface\STAT'			
	Name	Data Type	Address
+	arrCommand	Array [1..300] Of Byte	24.0
+	arrRecord	Array [1..300] Of Byte	324.0
+	fbCCOM	SICK CCOM TCP	624.0
+	fbTON	TON	758.0

Figure 10: Receiving reading results > 200 bytes (change to function block declaration)

The newly defined array lengths must be entered into network 3 of the SICK RFU6XX TCP function block.

```

Network 3: CONFIGURATION

- Configure the length of the "Record" array
- Configure the length of the "Command" array
- Configure the length of the "Reading Result" array
- Configure [STX]/[ETX] framing flag

PLEASE NOTE:
"Record" array >= "Command" array
"Record" array >= "Reading Result" array (external DB)

/-- LENGTH OF THE RECORD ARRAY
L 300
T #iArrayRecLen

/-- LENGTH OF THE COMMAND ARRAY
L 300
T #iArrayComLen

/-- LENGTH OF THE READING RESULT ARRAY
L 200
T #iArrayReadLen

/-- FRAMING
SET // Add framing
= #bAddFraming

```

Figure 11: Receiving reading results > 200 bytes (change to block code)

After modification, the instance of the function block must be updated. Subsequently, the modified user data block and the function block must be transferred to the PLC again, together with the updated instance.

## 5 Parameters

Parameter	Declaration	Data type	Memory area	Description
EN	INPUT	BOOL	I,M,D,L, const.	Enable input (LD and FBD)
ID	INPUT	WORD	I,M,D,L, const.	Connection ID for configured TCP connection (see communication diagnostics Figure 3 or ID parameter TCON FB)
CAN_ID	INPUT	INT	I,M,D,L, const.	CAN ID of the sensor to be addressed  If no CAN network is used, the CAN ID is B#16#00.  The master or multiplexer is always addressed with CAN ID B#16#00, even if it has been assigned another CAN ID.
TOUT	INPUT	TIME	I,M,D,L, const.	Period of time, after which a timeout error is triggered
START_REQ	INPUT	BOOL	I,M,D,L	Rising edge: Selected block function is executed
TRIG_ON	INPUT	BOOL	I,M,D,L, const.	Block function: Execute a device trigger (open trigger window).
TRIG_OFF	INPUT	BOOL	I,M,D,L, const.	Block function: Execute a device trigger (close trigger window).  The result sent from the device (SOPAS output format) is stored in the "ReadingResult.arrResult" variable of the user data DB (DB74).
RD_TAG	INPUT	BOOL	I,M,D,L, const.	Block function: Read tag content.  This function only works if the parameters of the "ReadTag" structure for the transferred data block have been assigned valid values (see chapter 4.5.4).  The selected addressing mode determines which transponder is to be read (see chapter 4.5.1).
WR_TAG	INPUT	BOOL	I,M,D,L, const.	Block function: Write tag content.  This function only works if the parameters of the "WriteTag" structure for the transferred data block have been assigned valid values (see chapter 4.5.5).  The selected addressing mode determines which transponder is to be written to (see chapter 4.5.1).

Parameter	Declaration	Data type	Memory area	Description
COM_TEST	INPUT	BOOL	I,M,D,L, const.	Block function: Execute a communication test.  REQ_DONE = TRUE: Communication OK  REQ_DONE = FALSE: Communication not OK
FREE_COMMAND	INPUT	BOOL	I,M,D,L, const.	Block function: Execute a free command.  This function only works if valid data has been assigned to the iCommandLength and arrCommand parameters in the structure (FreeCommand) within the user data block (DB74) (see chapter 4.5.6).  Following successful transfer, the command response (REQ_DONE = TRUE) is made available in the RESULT area of the data block.
DATA	INPUT	BLOCK_DB	Const.	Transfers the accompanying user data block that is required to configure the block functions and store the reading results (DB74)
RD_DONE	OUTPUT	BOOL	Q,M,D,L	Rising edge: New reading result received
REQ_DONE	OUTPUT	BOOL	Q,M,D,L	Indicates whether the selected block function has been successfully completed  TRUE: Successfully completed FALSE: Not completed
REQ_BUSY	OUTPUT	BOOL	Q,M,D,L	Command in progress
ERROR	OUTPUT	BOOL	Q,M,D,L	Error bit:  0: No error 1: Aborted with error
ERROR_CODE	OUTPUT	WORD	Q,M,D,L	Error status (see "Error codes")
ENO	OUTPUT	BOOL	Q,M,D,L	Enable output (LD and FBD)

*Table 6: Block parameters*

## 6 Error codes

The ERRORCODE parameter contains the following error information:

Error code	Brief description	Description
W#16#0000	No error	No error
W#16#0001	Timeout error	<p>Command could not be executed within the selected timeout period</p> <p>Possible causes:</p> <ul style="list-style-type: none"> <li>- Device is not connected to the PLC</li> <li>- Incorrect communication parameters</li> <li>- CAN bus station not present</li> </ul>
W#16#0002	Internal block error	Internal block error
W#16#0003	No block function selected, or more than one block function selected	Only one block function can be executed at a time.
W#16#0004	Received reading result > reading result array	The reading result received is longer than 200 bytes. See chapter 4.6 for information on how to receive longer reading results.
W#16#0005	100 < FreeCommand. iCommandLength <=0	<p>Length of free command is invalid</p> <p>Valid range: [1...100]</p>
W#16#0006	Free command response > 100 bytes	The response to the free command sent is longer than 100 bytes.
W#16#0007	63 < CAN_ID < 0	<p>Invalid CAN ID</p> <p>Valid range: [0..63]</p>
W#16#0008	Reserved	Reserved
W#16#0009	Communication error	<p>Communication could not be established with the device.</p> <p>Possible causes:</p> <ul style="list-style-type: none"> <li>- Invalid ID parameter</li> <li>- Connection not established</li> <li>- A telegram &gt; arrRecord was received.</li> </ul>
W#16#XX0A	Device error	<p>A device error occurred ("sFA XX").</p> <p><b>XX</b> = device error (see device documentation)</p>

Error code	Brief description	Description
W#16#000B	Invalid command response	<p>The selected function was not executed.</p> <p>The following causes are possible, depending on the function:</p> <ul style="list-style-type: none"> <li>- Incorrect trigger setting in the SOPAS device configuration</li> <li>- Device is not in "Run mode"</li> <li>- Send/receive power insufficient</li> <li>- Tag not long enough in field</li> <li>- Attempt to access a non-existent tag area (check nStartWord and nWordCount parameters)</li> <li>- Selected antenna cannot access the selected tag (check nAntenna parameter)</li> <li>- Invalid UII (check Mode.arrUII and Mode.iUIILength)</li> </ul>
W#16#000C – W#16#000F	Reserved	Reserved
W#16#0010	60 < Mode.iUIILength < 0	<p>UII length is invalid</p> <p>Valid range: [0..60]</p>
W#16#0011	3 < ReadTag.nBank < 0	<p>Invalid bank (read tag)</p> <p>Valid range: [0..3]</p>
W#16#0012	32 < ReadTag.nWordCount <= 0	<p>The function block can read a maximum of 32 words (64 bytes) from the tag.</p> <p>Valid range [1..32]</p>
W#16#0013	Invalid retry (ReadTag.nRetry)	<p>Invalid retry parameter (read tag)</p> <p>Valid range: Low nibble = [0..7] High nibble = [0..5]</p>
W#16#0014	15 < ReadTag.nAntenna < 1	<p>Invalid antenna selection (read tag)</p> <p>Valid range: [1..15]</p>
W#16#0015	3 < WriteTag.nBank < 0	<p>Invalid bank (write tag)</p> <p>Valid range: [0..3]</p>
W#16#0016	32 < WriteTag.nWordCount <= 0	<p>The function block can write a max. of 32 words (64 bytes) to the tag.</p> <p>Valid range [1..32]</p>



Error code	Brief description	Description
W#16#0017	Invalid retry (WriteTagTag.nRetry)	Invalid retry parameter (write tag)  Valid range: Low nibble = [0..7] High nibble = [0..5]
W#16#0018	15 < WriteTag. nAntenna < 1	Invalid antenna selection (write tag)  Valid range: [1..15]
W#16#0019	Invalid output format	Invalid SOPAS-ET output format. Check the output format (see chapter 4.5.3). This error can only occur in Mode 1.
W#16#001A	No tag in field	There are no tags in the receiving range of the RFU. This error can only occur in Mode 1.
W#16#001B	There is more than one tag in the field or the RSSImin evaluation condition has not been met.	This error can signify several different things: <ul style="list-style-type: none"> <li>- There is more than one tag in the receiving range of the RFU.</li> <li>- The RSSImin evaluation condition has not been met (see SOPAS-ET).</li> </ul> <p>This error can only occur in Mode 1.</p>

*Table 7: Error codes*

## 7 Examples

Figure 13 shows an example of a connected SICK RFU6XX TCP function block. The TCP connection to the SICK sensor is established with FB65 (TCON) during PLC startup (see Figure 12 / Figure 13). A zero is entered for the CAN ID because the RFU is not operating on a CAN network.

### Program call:

```
OB100 : "Complete Restart"

Comment:

Network 1: TCP VERBINDUNG HERSTELLEN | ESTABLISHING A TCP CONNECTION
Herstellen einer TCP Verbindung nach jedem SPS restart.
---
Open TCP connection after every PLC restart.

SET
= "TCON_PARAMETER".CONNECT.REQ DB2.DBX64.0
```

Figure 12: Start of the connection setup in OB100

```
Network 1: HERSTELLEN EINER TCP VERBINDUNG | OPEN TCP CONNECTION
Herstellen einer TCP Verbindung mittels FB65 (TCON)
---
Open TCP connection via FB65 (TCON)

// SET IP ADDRESS OF THE RFU
L 192
T "TCON_PARAMETER".CONNECT.TCON_PARAMETER.rem_staddr[1]
L 168
T "TCON_PARAMETER".CONNECT.TCON_PARAMETER.rem_staddr[2]
L 10
T "TCON_PARAMETER".CONNECT.TCON_PARAMETER.rem_staddr[3]
L 152
T "TCON_PARAMETER".CONNECT.TCON_PARAMETER.rem_staddr[4]

// SET ETHERNET CONNECTION PORT OF THE RFU
L 2112
T DB65.DBW 40

CALL "TCON" , DB165
REQ := "TCON_PARAMETER".CONNECT.REQ
ID := W#16#1
DONE := "TCON_PARAMETER".CONNECT.DONE
BUSY := "TCON_PARAMETER".CONNECT.BUSY
ERROR := "TCON_PARAMETER".CONNECT.ERROR
STATUS := "TCON_PARAMETER".CONNECT.STATUS
CONNECT := "TCON_PARAMETER".CONNECT.TCON_PARAMETER

CLR
= "TCON_PARAMETER".CONNECT.REQ
```

Figure 13: FB65 (TCON) call for creating a TCP connection

Netzwerk 2 : AUFRUF CCOM\_TCP FB | CALL CCOM\_TCP FB

Aufruf des CoLa Funktionsbausteins  
---  
Call of the CoLa function block




Figure 14: Example of a connected SICK RFU6XX TCP function block

## 7.1 Reading tag content

First, it is necessary to determine which transponder the system is to communicate with. If bit Mode.bMode = FALSE, then the system will communicate with the transponder that is currently located in the RFID sensor's reading range. The RFU must be specially configured in SOPAS-ET (see chapters 4.5.2 and 4.5.3) for this mode.

```
// ===== Mode =====
DB74.DBX 0.0 "SICK RFU DATA".Mode.bMode BOOL false
```

Figure 15: Selection of communication mode

Then, it is necessary to define what content is to be read out of the transponder.

Bank: 3 (user memory)  
 Tag range: 0 ... 6 words (12 bytes)  
 Number of retries: 0x57 (5 changes of channel with 7 retries per channel)  
 Antenna selection: 1 (antenna 1)

```
// ===== Read Tag =====
```

DB74.DBB	76	"SICK RFU DATA".ReadTag.nBank	DEC	3
DB74.DBW	78	"SICK RFU DATA".ReadTag.nStartWord	DEC	0
DB74.DBB	80	"SICK RFU DATA".ReadTag.nWordCount	DEC	6
DB74.DBB	81	"SICK RFU DATA".ReadTag.nRetry	HEX	B#16#57
DB74.DBB	82	"SICK RFU DATA".ReadTag.nAntenna	DEC	1

Figure 16: Definition of reading parameters

The reading function (bRdTag) is executed as soon as the "bRequest" bit is triggered with a rising edge.

```
// SICK RFU6XX PNDP Function Block Example
```

MV	16	"iCanID"	DEC	0
M	10.0	"bRequest"	BOOL	true
M	10.2	"bReqDone"	BOOL	true
M	10.3	"bReqBusy"	BOOL	false
M	10.4	"bError"	BOOL	false
MV	14	"nErrorcode"	HEX	Vw#16#0000

```
// Selection of the FB action to be executed
```

M	12.1	"bTriggerOn"	BOOL	false
M	12.2	"bTriggerOff"	BOOL	false
M	12.3	"bRdTag"	BOOL	true
M	12.5	"bWrTag"	BOOL	false
M	12.4	"bComTest"	BOOL	false
M	12.6	"bFreeCommand"	BOOL	false

Figure 17: Starting the block function

The reading function is completed as soon as bit bReqDone = TRUE. The read tag content is available in the "ReadTag.arrData" array of the user data block. The "ReadTag.iDataLength" variable specifies how many bytes have been received and are valid.

```
// ===== Read Tag =====
```

DB74.DBB	76	"SICK RFU DATA".ReadTag.nBank	DEC	3
DB74.DBW	78	"SICK RFU DATA".ReadTag.nStartWord	DEC	0
DB74.DBB	80	"SICK RFU DATA".ReadTag.nWordCount	DEC	6
DB74.DBB	81	"SICK RFU DATA".ReadTag.nRetry	HEX	B#16#57
DB74.DBB	82	"SICK RFU DATA".ReadTag.nAntenna	DEC	1
DB74.DBW	84	"SICK RFU DATA".ReadTag.iDataLength	DEC	12
DB74.DBB	86	"SICK RFU DATA".ReadTag.arrData[1]	CHARACTER	'H'
DB74.DBB	87	"SICK RFU DATA".ReadTag.arrData[2]	CHARACTER	'e'
DB74.DBB	88	"SICK RFU DATA".ReadTag.arrData[3]	CHARACTER	'l'
DB74.DBB	89	"SICK RFU DATA".ReadTag.arrData[4]	CHARACTER	'l'
DB74.DBB	90	"SICK RFU DATA".ReadTag.arrData[5]	CHARACTER	'o'
DB74.DBB	91	"SICK RFU DATA".ReadTag.arrData[6]	CHARACTER	' '
DB74.DBB	92	"SICK RFU DATA".ReadTag.arrData[7]	CHARACTER	'W'
DB74.DBB	93	"SICK RFU DATA".ReadTag.arrData[8]	CHARACTER	'o'
DB74.DBB	94	"SICK RFU DATA".ReadTag.arrData[9]	CHARACTER	'r'
DB74.DBB	95	"SICK RFU DATA".ReadTag.arrData[10]	CHARACTER	'l'
DB74.DBB	96	"SICK RFU DATA".ReadTag.arrData[11]	CHARACTER	'd'
DB74.DBB	97	"SICK RFU DATA".ReadTag.arrData[12]	CHARACTER	' '
DB74.DBB	98	"SICK RFU DATA".ReadTag.arrData[13]	CHARACTER	B#16#00
DB74.DBB	99	"SICK RFU DATA".ReadTag.arrData[14]	CHARACTER	B#16#00
DB74.DBB	100	"SICK RFU DATA".ReadTag.arrData[15]	CHARACTER	B#16#00

Figure 18: Read tag content

## 7.2 Writing tag content

First, it is necessary to determine which transponder the system is to communicate with. If bit Mode.bMode = TRUE, then the system will communicate with the specified transponder, the Ull of which is known in advance (in this case: 12345678).

```
// ===== Mode =====
```

DB74.DBX	0.0	"SICK RFU DATA".Mode.bMode	BOOL	true
DB74.DBW	2	"SICK RFU DATA".Mode.iUllLength	DEC	8
DB74.DBB	8	"SICK RFU DATA".Mode.arrUll[1]	CHARACTER	'1'
DB74.DBB	9	"SICK RFU DATA".Mode.arrUll[2]	CHARACTER	'2'
DB74.DBB	10	"SICK RFU DATA".Mode.arrUll[3]	CHARACTER	'3'
DB74.DBB	11	"SICK RFU DATA".Mode.arrUll[4]	CHARACTER	'4'
DB74.DBB	12	"SICK RFU DATA".Mode.arrUll[5]	CHARACTER	'5'
DB74.DBB	13	"SICK RFU DATA".Mode.arrUll[6]	CHARACTER	'6'
DB74.DBB	14	"SICK RFU DATA".Mode.arrUll[7]	CHARACTER	'7'
DB74.DBB	15	"SICK RFU DATA".Mode.arrUll[8]	CHARACTER	'8'
DB74.DBB	16	"SICK RFU DATA".Mode.arrUll[9]	CHARACTER	B#16#00
DB74.DBB	17	"SICK RFU DATA".Mode.arrUll[10]	CHARACTER	B#16#00

Figure 19: Specification of transponder Ull

Subsequently, it is necessary to define what content is to be written to the tag and where it should be stored.

Bank: 3 (user memory)  
 Tag range: 0 ... 3 words (6 bytes/character)  
 Number of retries: 0x57 (5 changes of channel with 7 retries per channel)  
 Antenna selection: 1 (antenna 1)  
 Content to be written: "Tag 01" (6 ASCII characters)

```
// ===== Write Tag =====
```

DB74.DBB	150	"SICK RFU DATA".WriteTag.nBank	DEC	3
DB74.DBW	152	"SICK RFU DATA".WriteTag.nStartWord	DEC	0
DB74.DBB	154	"SICK RFU DATA".WriteTag.nWordCount	DEC	3
DB74.DBB	155	"SICK RFU DATA".WriteTag.nRetry	HEX	B#16#57
DB74.DBB	156	"SICK RFU DATA".WriteTag.nAntenna	HEX	B#16#01
DB74.DBB	158	"SICK RFU DATA".WriteTag.arrData[1]	CHARACTER	'T'
DB74.DBB	159	"SICK RFU DATA".WriteTag.arrData[2]	CHARACTER	'a'
DB74.DBB	160	"SICK RFU DATA".WriteTag.arrData[3]	CHARACTER	'g'
DB74.DBB	161	"SICK RFU DATA".WriteTag.arrData[4]	CHARACTER	' '
DB74.DBB	162	"SICK RFU DATA".WriteTag.arrData[5]	CHARACTER	'0'
DB74.DBB	163	"SICK RFU DATA".WriteTag.arrData[6]	CHARACTER	'1'

Figure 20: Definition of reading parameters

The write function (bWrTag) is executed as soon as the "bRequest" bit is triggered with a rising edge.










// SICK RFU6XX PNDP Function Block Example				
MW	16	"iCanID"	DEC	0
M	10.0	"bRequest"	BOOL	 true
M	10.2	"bReqDone"	BOOL	 true
M	10.3	"bReqBusy"	BOOL	 false
M	10.4	"bError"	BOOL	 false
MW	14	"nErrorcode"	HEX	VW#16#0000
// Selection of the FB action to be executed				
M	12.1	"bTriggerOn"	BOOL	 false
M	12.2	"bTriggerOff"	BOOL	 false
M	12.3	"bRdTag"	BOOL	 false
M	12.5	"bWrTag"	BOOL	 true
M	12.4	"bComTest"	BOOL	 false
M	12.6	"bFreeCommand"	BOOL	false

Figure 21: Starting the block function

The write function is completed as soon as bit bReqDone = TRUE.